Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 28/02/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

: EE(Project)/Ynk Zone/wo/12/2018-19

: 23-02-2019

: Column Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 28/02/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	21/02/2019	28/02/2019	149.85 X 149.12 X 151.28	22345	**8.320**	527.4	23.6	22.7
Column Concrete	M25	21/02/2019	28/02/2019	151.48 X 149.65 X 150.20	22670	**8.556**	511.8	22.6	
Column Concrete	M25	21/02/2019	28/02/2019	151.84 X 151.56 X 149.60	23013	**8.904**	507.2	22.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-06-20-26 **Date: 21/03/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

mmer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 23-02-2019

mmer ID : Column Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 21/03/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	21/02/2019	21/03/2019	150.49 X 149.70 X 151.87	22528	**8.712**	626.0	27.8	27.4
Column Concrete	M25	21/02/2019	21/03/2019	151.12 X 149.74 X 151.57	22629	**8.745**	591.6	26.1	
Column Concrete	M25	21/02/2019	21/03/2019	149.42 X 150.01 X 149.74	22415	**8.409**	632.7	28.2	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 10/06/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

: EE(Project)/Ynk Zone/wo/12/2018-19

: 05-06-2019

: Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	03/06/2019	10/06/2019	150.16 X 151.06 X 149.41	22683	**8.307**	530.7	23.4	22.9
Roof Concrete	M25	03/06/2019	10/06/2019	151.72 X 149.92 X 149.86	22747	**8.787**	508.9	22.4	
Roof Concrete	M25	03/06/2019	10/06/2019	150.83 X 150.73 X 151.03	22734	**8.612**	522.4	23.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

ID	:	**CP-2019-06-20-26** **Date: 10/06/2019**
Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Receipt	:	05-06-2019
ID	:	Roof Concrete
Type /Size	:	150X150X150 mm
grade/Age	:	M25 / 7 Days Compressive Strength
to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Test	:	10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	03/06/2019	10/06/2019	149.85 X 151.52 X 149.69	22706	**9.095**	522.9	23.0	22.9
Roof Concrete	M25	03/06/2019	10/06/2019	149.46 X 150.61 X 150.14	22511	**8.398**	512.9	22.8	
Roof Concrete	M25	03/06/2019	10/06/2019	149.10 X 151.03 X 150.23	22518	**8.176**	515.2	22.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-06-20-26 **Date: 10/06/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Reference : EE(Project)/Ynk Zone/wo/12/2018-19

: 05-06-2019

: Roof Concrete

/Size : 150X150X150 mm

/Age : M25 / 7 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	03/06/2019	10/06/2019	149.33 X 151.90 X 151.62	22683	**8.566**	522.5	23.0	22.6
Roof Concrete	M25	03/06/2019	10/06/2019	151.73 X 151.42 X 151.85	22976	**9.047**	505.5	22.0	
Roof Concrete	M25	03/06/2019	10/06/2019	151.97 X 151.10 X 149.51	22963	**8.693**	524.4	22.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 10/06/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 05-06-2019

ID : Roof Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	03/06/2019	10/06/2019	150.57 X 151.82 X 150.16	22858	**8.281**	528.8	23.1	22.5
Roof Concrete	M25	03/06/2019	10/06/2019	150.49 X 150.20 X 149.97	22604	**8.586**	500.5	22.1	
Roof Concrete	M25	03/06/2019	10/06/2019	151.28 X 151.27 X 151.84	22884	**8.144**	511.1	22.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-06-20-26 **Date: 10/06/2019**

Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 05-06-2019

ID : Roof Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	03/06/2019	10/06/2019	150.36 X 151.17 X 149.69	22731	**8.197**	544.2	23.9	23.2
Roof Concrete	M25	03/06/2019	10/06/2019	150.21 X 149.67 X 150.40	22482	**8.634**	516.5	23.0	
Roof Concrete	M25	03/06/2019	10/06/2019	151.99 X 149.98 X 150.63	22795	**8.362**	514.8	22.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 11/06/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 06-06-2019

ID : Roof Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 11/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	04/06/2019	11/06/2019	151.23 X 151.12 X 149.96	22854	**8.996**	534.8	23.4	22.7
Roof Concrete	M25	04/06/2019	11/06/2019	151.67 X 150.17 X 149.73	22777	**8.428**	512.2	22.5	
Roof Concrete	M25	04/06/2019	11/06/2019	149.88 X 149.88 X 150.60	22464	**8.391**	498.9	22.2	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 11/06/2019

	:	CP-2019-06-20-26
Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Receipt	:	06-06-2019
ID	:	Roof Concrete
Type /Size	:	150X150X150 mm
grade/Age	:	M25 / 7 Days Compressive Strength
to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Test	:	11/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	04/06/2019	11/06/2019	150.58 X 151.54 X 149.96	22818	**8.719**	531.7	23.3	22.6
Roof Concrete	M25	04/06/2019	11/06/2019	149.92 X 149.66 X 149.51	22437	**8.251**	505.5	22.5	
Roof Concrete	M25	04/06/2019	11/06/2019	149.97 X 151.51 X 150.48	22721	**8.954**	501.3	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 11/06/2019**

Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 06-06-2019

ID : Roof Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 7 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 11/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	04/06/2019	11/06/2019	149.87 X 151.67 X 151.82	22731	**8.722**	542.2	23.9	23.0
Roof Concrete	M25	04/06/2019	11/06/2019	149.97 X 150.58 X 149.32	22582	**8.722**	502.7	22.3	
Roof Concrete	M25	04/06/2019	11/06/2019	151.49 X 151.37 X 150.27	22930	**8.999**	523.3	22.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO * Sig..... Date..... * BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

	:	**CP-2019-06-20-26** **Date: 14/03/2019**
Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Receipt	:	09-03-2019
ID	:	Balancing Tank Roof Concrete
Type /Size	:	150X150X150 mm
grade/Age	:	M25 / 7 Days Compressive Strength
to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Test	:	14/03/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	150.30 X 150.33 X 150.81	22595	**8.948**	528.9	23.4	22.9
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	151.64 X 150.16 X 150.11	22770	**9.037**	518.1	22.8	
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	150.18 X 151.84 X 150.57	22803	**8.975**	514.2	22.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-06-20-26 **Date: 04/04/2019**

: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

eference : EE(Project)/Ynk Zone/wo/12/2018-19

ot : 09-03-2019

: Balancing Tank Roof Concrete

Size : 150X150X150 mm

Age : M25 / 28 Days Compressive Strength

IS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 04/04/2019

ification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
g Tank Roof ncrete	M25	07/03/2019	04/04/2019	150.40 X 149.74 X 151.78	22520	**8.712**	617.1	27.4	27.4
g Tank Roof ncrete	M25	07/03/2019	04/04/2019	151.13 X 149.27 X 151.94	22558	**8.745**	589.7	26.1	
g Tank Roof ncrete	M25	07/03/2019	04/04/2019	150.31 X 150.69 X 150.13	22650	**8.409**	650.2	28.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

	: CP-2019-06-20-26	**Date: 14/03/2019**
Name	: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07	
	: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054	
's Reference	: EE(Project)/Ynk Zone/wo/12/2018-19	
Receipt	: 09-03-2019	
ID	: Balancing Tank Roof Concrete	
Type /Size	: 150X150X150 mm	
grade/Age	: M25 / 7 Days Compressive Strength	
to BIS codes	: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5	
test	: 14/03/2019	

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	151.57 X 151.67 X 150.18	22988	**8.363**	532.4	23.2	22.7
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	151.92 X 151.52 X 150.60	23020	**8.247**	523.1	22.7	
Balancing Tank Roof Concrete	M25	07/03/2019	14/03/2019	151.78 X 150.67 X 149.33	22869	**8.807**	507.7	22.2	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-06-20-26 **Date: 04/04/2019**

Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 09-03-2019

ner ID : Balancing Tank Roof Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 28 Days Compressive Strength

ce to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 04/04/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
lancing Tank Roof Concrete	M25	07/03/2019	04/04/2019	151.01 X 151.11 X 150.61	22818	**8.712**	630.6	27.6	27.6
lancing Tank Roof Concrete	M25	07/03/2019	04/04/2019	150.65 X 151.35 X 150.97	22801	**8.745**	605.3	26.5	
lancing Tank Roof Concrete	M25	07/03/2019	04/04/2019	149.42 X 149.54 X 149.01	22345	**8.409**	637.4	28.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig Date BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-06-20-26** **Date: 04/04/2019**

Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

er's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Receipt : 30-03-2019

er ID : Staircase Concrete

Type /Size : 150X150X150 mm

grade/Age : M25 / 7 Days Compressive Strength

ce to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

test : 04/04/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Staircase Concrete	M25	28/03/2019	04/04/2019	150.82 X 149.93 X 149.77	22612	**8.771**	523.0	23.1	22.6
Staircase Concrete	M25	28/03/2019	04/04/2019	151.69 X 151.90 X 149.05	23042	**8.458**	516.6	22.4	
Staircase Concrete	M25	28/03/2019	04/04/2019	150.15 X 151.11 X 149.90	22689	**8.377**	503.4	22.2	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

CIVIL Pro Sig..... Date..... BANGALORE

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 25/04/2019

ID	:	**CP-2019-06-20-26**
Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
mer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
f Receipt	:	30-03-2019
mer ID	:	Staircase Concrete
e Type /Size	:	150X150X150 mm
e grade/Age	:	M25 / 28 Days Compressive Strength
nce to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
f test	:	25/04/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Staircase Concrete	M25	28/03/2019	25/04/2019	149.12 X 150.22 X 149.68	22401	**8.712**	623.7	27.8	27.7
Staircase Concrete	M25	28/03/2019	25/04/2019	150.12 X 150.05 X 150.84	22525	**8.745**	603.5	26.8	
Staircase Concrete	M25	28/03/2019	25/04/2019	151.07 X 151.48 X 149.34	22885	**8.409**	650.5	28.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

D	:	**CP-2019-06-20-26** **Date: 10/06/2019**
t Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
ss	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
mer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
f Receipt	:	06-06-19
mer ID	:	Staircase Concrete
le Type /Size	:	150X150X150 mm
le grade/Age	:	M25 / 7 Days Compressive Strength
rence to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
f test	:	10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Staircase Concrete	M25	03/06/2019	10/06/2019	149.56 X 151.60 X 150.03	22674	**8.841**	530.9	23.4	22.5
Staircase Concrete	M25	03/06/2019	10/06/2019	150.63 X 151.61 X 151.50	22838	**8.559**	503.3	22.0	
Staircase Concrete	M25	03/06/2019	10/06/2019	151.36 X 150.03 X 150.40	22708	**8.794**	502.7	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****